

Ročný protokol emisných hodnôt pre RP za :

2012

Palivo		Bez TAP				Spolustaľovanie TAP				
ZL	SPH - 30 min	CO	NO _x	SO ₂	TZL	CO	NO _x	SO ₂	TZL	TOC
EL	[mg/Nm ³]	-	1300	400	50	-	800	50	30	30
I	[%EL]	10	20	20	30	10	20	20	30	30
N SPH > 2 EL+I		-	0	0	2	-	-	-	-	-
N PDH > EL+I		-	6	0	1	-	124	6	14	0
mesiace s % < 95% (%SPH < 1.2EL+I)			IX ,X ,XII ,		V ,	-	-	-	-	-
N F PDH		0	0	0	0	0	0	0	0	0
% (F) z N _{stabil} (≤5%) / Účinnosť AMS		0,96 / 99,04	0,96 / 99,04	0,96 / 99,04	0,96 / 99,04	0,56 / 99,44	0,56 / 99,44	0,56 / 99,44	0,50 / 99,50	0,50 / 99,50
c - priem. hm. koncent. ZL ≤ EL [mg/m _{ns} ³]		23.9	746.2	4.3	6.4	20.5	426.0	5.3	5.3	2.0
množstvo ZL ≤ EL [kg]		783.5	15,110.7	142.3	203.1	19,453.6	75,922.0	4,803.7	4,522.3	1,942.7
Q Spalin ≤ EL [tis. m ³]		32,735	20,251	32,735	31,980	949,860	178,216	911,563	851,636	949,860
c - priem. hm. koncent. ZL > EL [mg/m _{ns} ³]		0.0	727.9	0.0	64.7	-	513.1	30.7	28.3	0.0
množstvo ZL > EL [kg]		0.0	9,087.7	0.0	48.9	-	395,939.2	1,176.2	2,778.4	0.0
Q Spalin > EL [tis. m ³]		0	12,484	0	755	-	771,644	38,298	98,224	0

Počet hodín za rok: 3025.5						Priemerné mesačné emisné hodnoty [mg/Nm ³]				Priemerné mesačné emisné hodnoty [mg/Nm ³]				
Stav:	Bez	Ust	Náb	ZmQ	Odst	Meranie bez TAP				Meranie so spolustaľovaním TAP				
Deň	-	'''	N	Q	Z	CO	NO _x	SO ₂	TZL	CO	NO _x	SO ₂	TZL	TOC
Jan-12	1488.	0/0	0.	0.	0.									
Feb-12	1392.	0/0	0.	0.	0.									
Mar-12	538.	16/921	0.	0.	0.	26.2	1,020.0	8.8	5.5	27.6	893.1	12.7	6.9	3.3
Apr-12	590.	51/798	0.	0.	0.	22.5	1,157.5	5.8	16.2	25.0	945.3	9.7	15.3	2.0
May-12	933.	4/551	0.	0.	0.	63.4	1,078.1	4.5	32.9	23.0	891.9	5.6	23.9	2.6
Jun-12	694.	52/694	0.	0.	0.	38.8	1,022.5	5.3	19.2	22.5	912.8	5.3	16.7	3.0
Jul-12	903.	30/555	0.	0.	0.	35.0	977.4	5.1	0.7	38.8	897.4	7.2	1.1	5.4
Aug-12	802.	13/673	0.	0.	0.	21.5	1,151.8	4.1	9.7	27.9	865.7	5.4	18.6	3.1
Sep-12	598.	19/823	0.	0.	0.	53.2	1,159.6	5.5	32.3	49.0	839.9	10.7	18.2	4.2
Oct-12	747.	17/382	0.	342.	0.	42.1	1,047.4	7.4	3.1	54.2	846.5	7.9	5.0	5.2
Nov-12	1068.	1/196	0.	175.	0.	66.2	825.6	1.0	3.5	39.7	1,070.7	12.3	3.1	5.7
Dec-12	1043.	5/250	0.	190.	0.	96.3	2,104.8	50.8	21.6	56.9	772.7	50.4	46.7	3.1
SUMA	10796.	208/5 843	0.	707.	0.	46.5	1,154.5	9.8	14.5	36.5	893.6	12.7	15.6	3.8

Meranie bez TAP	
EL je dodržaný, ak v kalend. roku:	žiadna SPH neprekročí hodnotu 2*EL+I
	žiadna PDH neprekročí hodnotu EL+I
	najmenej 95 % zo všetkých SPH za kalend. mesiac neprekročí 1,2 EL+I

Meranie s TAP	
EL je dodržaný, ak v kalend. roku:	žiadna PDH neprekročí hodnotu EL